



Fair  
Trading

Ref: NSW28523/1

## ADDENDUM TO CERTIFICATE OF APPROVAL: NSW28523 Particulars of Modification(s)

Model No. IT FIT 11/220-240/500 CS I being similar to original article Model No. IT FIT 15/220-240/700 CS I except for Tc 75A°C and output options below:

- Option 1: Irated 350mA, Prated 7.35W.
- Option 2: Irated 400mA, Prated 8.40W.
- Option 3: Irated 450mA, Prated 9.45W.
- Option 4: Irated 500mA, Prated 10.50W.

Model No. IT FIT 7/220-240/700 CS I being similar to original article Model No. IT FIT 15/220-240/700 CS I, except for U<sub>rated</sub>: 2.5-11V, Tc 70°C and output options below:

- Option 1: Irated 350mA, Prated 3.85W.
- Option 2: Irated 400mA, Prated 4.40W.
- Option 3: Irated 450mA, Prated 4.95W.
- Option 4: Irated 500mA, Prated 5.50W.
- Option 5: Irated 550mA, Prated 6.05W.
- Option 6: Irated 600mA, Prated 6.60W.
- Option 7: Irated 650mA, Prated 7.15W.
- Option 8: Irated 700mA, Prated 7.70W.

Model No. IT FIT 4/220-240/400 CS I being similar to original article Model No. IT FIT 15/220-240/700 CS I, except U<sub>rated</sub>: 2.5-10V, Tc 70°C and output options below:

- Option 1: Irated 100mA, Prated 1W.
- Option 2: Irated 200mA, Prated 2W.
- Option 3: Irated 300mA, Prated 3W.
- Option 4: Irated 400mA, Prated 4W.

This certificate will expire on 11/05/2026

Approved pursuant to Clause 15 (1) of the Gas and Electricity (Consumer Safety) Regulation 2018:  
11 May 2021

For Secretary, Department of Customer Service



11 May 2021