

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Independent LED driver
Name and address of the applicant	Osram GmbH Marcel-Breuer-Straße 6, 80807 München Germany
Name and address of the manufacturer	Osram GmbH Marcel-Breuer-Straße 6, 80807 München Germany
Ratings and principal characteristics	Independent, SELV, safety isolating non-inherently short circuit proof, 110 °C thermally protection, constant current type, MM mark, Class II, IP20, Uout 60 Vdc; 220-240 V, 50/60 Hz, ta 50 °C, tc 70 °C, λ 0,95, In 0,05 A; Output 1: 100 mA, 27-40 Vdc, 4 W; Output 2: 120 mA, 27-40 Vdc, 4,8 W; Output 3: 155 mA, 27-40 Vdc, 6,2 W; Output 4: 180 mA, 27-40 Vdc, 7,2 W
Trademark (if any)	OSRAM
Customer's Testing Facility (CTF) Stage used	
Model / Type Ref.	OT FIT 7/220-240/180 CS PC
A sample of the product was tested and found to be in conformity with	IEC 61347-1:2015, IEC 61347-1:2015/AMD1:2017, IEC 61347-2-13:2014, IEC 61347-2-13:2014/AMD1:2016 <u>National differences:</u> EU Group Differences, EU Special National Conditions, AU, GB, NZ
As shown in the Test Report Ref. No. which forms part of this Certificate	4384128.50

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051, NL-6825 MJ Arnhem, Netherlands