



Ref. Certif. No.

SG PSB-LE-04172

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Power supplies (Constant Current LED Power Supply)
Name and address of the applicant	Osram GmbH Marcel-Breuer-Str. 6 80807 München GERMANY
Name and address of the manufacturer	Osram GmbH Marcel-Breuer-Str. 6, 80807 München, GERMANY
Ratings and principal characteristics	Rated Input Voltage : 220-240VAC/DC Rated Frequency : 0/50/60Hz Rated Input Current : See test report for details Rated Output : See test report for details Protection against Electric Shock : Class II (with endcap); SELV Degree of Protection : IP20 (with endcap) Method of Installation : See test report for details Type of Output : Constant current type ta : See test report for details tc : 80°C
Model/type Ref.	IT DALI 12/220-240/300 CS; IT DALI 30/220-240/700 CS; IT DALI 42/220-240/1050 CS
A sample of the product was tested and found to be in conformity with	IEC 61347-1:2015 IEC 61347-1:2015/AMD1:2017 IEC 61347-2-13:2014 IEC 61347-2-13:2014/AMD1:2016
as shown in the Test Report Ref. No. which forms part of this certificate	211-14220131-000

Page 1 of 2
This CB Test Certificate is issued by the National Certification Body

CBS 084117 0119 Rev. 00
Date, 2022-06-06

(Taylor Yao)



#OSRAM 0LQ(V) #744 #HILL.YU # #ECS #CB 2022-06-07 #Confirm valid copy #RL-Released 9C1 4412815-EN-00



Ref. Certif. No.

SG PSB-LE-04172

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

Trademark / Brand (Image)

OSRAM ICUTRONIC®

Page 2 of 2

This CB Test Certificate is issued by the National Certification Body

CBS 084117 0119 Rev. 00

Date, 2022-06-06

(Taylor Yao)



TÜV SÜD PSB Pte Ltd 15 International Business Park TÜV SÜD @ IBP Singapore 609937

PSB Singapore

#OSRAM 0LQ(V)

#744 #HILL.YU

#

#ECS #CB

2022-06-07 #Confirm valid copy

#RL-Released

9C1 4412815-EN-00