42 CS

30



File Ref: NSW28035/12 Contact: Admin Clerk Telephone: 02 9895 0722



Mr Darren Miruzzi Osram Pty Ltd Level 7, 91 Phillip Street PARRAMATTA NSW 2150

Dear Sir/Madam

MODIFICATION TO CERTIFICATE OF APPROVAL: NSW28035

Power Supply or Charger

Please find enclosed an addendum to the certificate as sought in your application.

Yours faithfully,

mal

15 July 2022

For Secretary, Department of Customer Service

Electrical & Gas Approvals, NSW Fair Trading, PO Box 972, Parramatta NSW 2124 02 9895 0722

Email: <u>energyapprovals@customerservice.nsw.gov.au</u> Website: <u>www.fairtrading.nsw.gov.au</u>

Ref: NSW28035/12



ADDENDUM TO CERTIFICATE OF APPROVAL: NSW28035 Particulars of Modification(s)

Model IT DALI 12/220-240/300 CS being similar to original article OTi DALI 50/220-240/1A4 LT2 FAN NFC, except $P_{rated}(max)$: 12.6W, I_{rated} : 300mA, U_{rated} : 9-42Vdc, In: 0.077A, Ta: -20 to +45°C, Tc= 80°C.

Model IT DALI 30/220-240/700 CS being similar to original article OTi DALI 50/220-240/1A4 LT2 FAN NFC, except $P_{rated}(max)$: 29.4W, I_{rated} : 700mA, U_{rated} : 15-42Vdc, In: 0.161A, Ta: -20 to +50°C, Tc= 80°C.

Model IT DALI 42/220-240/1050 CS being similar to original article OTi DALI 50/220-240/1A4 LT2 FAN NFC, except $P_{rated}(max)$: 42W, I_{rated} : 1050mA, U_{rated} : 15-40Vdc, In: 0.077A, Ta: -20 to +45°C, Tc= 80°C.

This certificate will expire on 11/09/2023

Approved pursuant to Clause 15 (1) of the Gas and Electricity (Consumer Safety) Regulation 2018:

15 July 2022

For Secretary, Department of Customer Service

Electrical & Gas Approvals, NSW Fair Trading, PO Box 972, Parramatta NSW 2124 02 9895 0722

Email: <u>energyapprovals@customerservice.nsw.gov.au</u> Website: <u>www.fairtrading.nsw.gov.au</u> #OSRAM OLQ(V)

9C1