

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Independent LED drivers
Name and address of the applicant	Osram GmbH Marcel-Breuer-Straße 6, 80807 München Germany
Name and address of the manufacturer	Osram GmbH Marcel-Breuer-Straße 6, 80807 München Germany
Ratings and principal characteristics	120-190 V, 190-277 V, 50/60 Hz, Class I, IP67, ta 60 °C, tc 90 °C, $\lambda \geq 0,95$, Independent, Auto-wound controlgear, constant current type, other details see "General product information" of test report.
Trademark (if any)	OSRAM
Customer's Testing Facility (CTF) Stage used	
Model / Type Ref.	EM 100/120-277/700 P7, EM 150/120-277/700 P7, EM 200/120-277/700 P7, EM 250/120-277/700 P7
Additional information (if necessary may also be reported on page 2)	<input type="checkbox"/> Additional information on page 2
A sample of the product was tested and found to be in conformity with	IEC 61347-1:2015, IEC 61347-1:2015/AMD1:2017, IEC 61347-2-13:2014, IEC 61347-2-13:2014/AMD1:2016 National differences: EU Group Differences, EU Special National Conditions, AU, KR, NZ
As shown in the Test Report Ref. No. which forms part of this Certificate	4384067.50

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051, NL-6825 MJ Arnhem, Netherlands