


**Lamp wiring: | Lampenverdrahtung:**



Max. permitted cable length in between ECG and lamp: 2.0 m (PIN 21, 22, 23); 1.0 m (PIN 24, 25, 26, 27)

Max. zulässige Leitungslänge zwischen EVG und Lampe: 2,0 m (PIN 21, 22, 23); 1,0 m (PIN 24, 25, 26, 27)