


# Lamp wiring | Lampenverdrahtung

## QTP5 1x49



Max. permitted cable length in between ECG and lamp: 2.0 m (PIN 21, 22); 1.0 m (PIN 23, 24)

Max. zulässige Leitungslänge zwischen EVG und Lampe: 2,0 m (PIN 21, 22); 1,0 m (PIN 23, 24)