

#744 #JULY.ZHU

#

CERTIFICATE

No. U6 084117 0132 Rev. 00

Holder of Certificate:

Osram GmbH

Marcel-Breuer-Str. 6 80807 München GERMANY

Certification Mark:



Product:

Power supplies (Constant Current LED Power Supply)

The product was voluntarily tested according to the listed standards. The product can be marked with the certification mark shown above. It is not permitted to alter the certification mark in any way. In addition, the certificate holder must not transfer the certificate to third parties. All applicable requirements of the testing and certification regulations of TÜV SÜD Group have to be complied. For details see: www.tuvsud.com/ps-cert

Test report no.:

64142225019101

Date,

2022-09-29

(Taylor Yao)

TÜV



#744 #JULY.ZHU

#

CERTIFICATE

No. U6 084117 0132 Rev. 00

Model(s):

IT FIT 60/220-240/1A4 CS

Brand Name:

OSRAM, ICUTRONIC

OSRAM **ICUTRONIC[®]**

Parameters:

Rated Input Voltage: 220-240VAC Rated Frequency: 50/60Hz Rated Input Current: See below table for details Rated Output: See below table for details Protection against Electric Shock: Class II (with endcap); SELV Degree of Protection: IP20 (with endcap) Method of Installation: Independent (with endcap); Built-in (without endcap) Type of Output: Constant current type ta: -20...+50°C tc: 80°C

| Model No. | Rated Input Current (A) | Output Voltage (VDC) | I _{rated} (mA) | P _{rated} (W) | U _{out} (VDC) |
|--------------------------|----------------------------|-------------------------|-------------------------|---------------------------|------------------------|
| IT FIT 60/220-240/1A4 CS | 0.25 | 27-57 | 825 | 47 | 70 |
| | 0.27 | 27-57 | 900 | 51 | |
| | 0.29 | 27-57 | 975 | 55 | |
| | 0.32 | 27-57 | 1050 | 60 | |
| | | 27-52 | 1100 | 57 | |
| | | 27-48 | 1200 | 57 | |
| | | 27-43 | 1300 | 56 | |
| | | 27-42 | 1400 | 59 | |

Tested according to: EN 61347-2-13:2014/A1:2017 EN 61347-1:2015/A1:2021 EN IEC 62384:2020

Production Facility(ies):

095962

πືΩນັ້ນ