

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product Power supplies

(24V Constant Voltage LED Power Supply)

Name and address of the applicant Inventronics GmbH

Parkring 31-33

85748 Garching by Munich

GERMANY

Name and address of the manufacturer Inventronics GmbH

Parkring 31-33, 85748 Garching by Munich, GERMANY

Name and address of the factory Eaglerise Electric & Electronic (China) Co.,Ltd. Beijiao Branch

No.4, East Huanzhen Road, Beijiao, Shunde, 528000 Foshan, Guangdong,

PEOPLE'S REPUBLIC OF CHINA

Ratings and principal characteristics Rated Input Voltage: 220-240VAC or 176-250VDC

Rated Frequency: 50/60Hz [for 220-240VAC] or 0Hz [for 176-250VDC]

Rated Input Current: See test report for details Rated Output: See test report for details Protection against Electric Shock: Class I; SELV

Degree of Protection: IP67 Method of Installation: Independent Type of Output: Constant voltage type

ta: -30...55°C

tc: See test report for details

Model/type Ref. OT 100/220-240/24 DIM P; OT 100/220-240/24 P;

OT 130/220-240/24 DIM P; OT 130/220-240/24 P; OT 250/220-240/24 DIM P; OT 250/220-240/24 P

A sample of the product was tested and found

to be in conformity with

IEC 61347-1:2015

IEC 61347-1:2015/AMD1:2017

IEC 61347-2-13:2014

IEC 61347-2-13:2014/AMD1:2016

as shown in the Test Report Ref. No. which forms part of this certificate

211-14230208-000

Page 1 of 2


This CB Test Certificate is issued by the National Certification Body

CBS 120825 0071 Rev. 00

Date, 2023-07-21











IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

Trademark / Brand (Image)

OSRAM OPTOTRONIC®

Page 2 of 2

This CB Test Certificate is issued by the National Certification Body

CBS 120825 0071 Rev. 00

Date,

2023-07-21

(Taylor Yao)

TÜV SÜD PSB Pte Ltd 15 International Business Park TÜV

TÜV SÜD @ IBP

Singapore 609937



PSB Singapore